



NOTES:

1. ABOVE DETAIL IS BASED ON 2" COMBINATION AIR/VACUUM RELEASE VALVE. CHANGE PIPE AND FITTINGS ACCORDINGLY FOR OTHER VALVE SIZES AND TYPES. VALVE SIZES TO BE DETERMINED BY THE ENGINEER AND APPROVED BY THE CITY PRIOR TO INSTALLATION.
2. THE MINIMUM DIMENSION FROM TOP OF PIPE TO FINISHED GRADE SHALL BE 4.0 FEET.

| | | |
|---|-------------|----------|
| CITY OF OCOEE UTILITIES DEPARTMENT | | |
| AIR OR COMBINATION AIR/VACUUM RELEASE VALVE DETAIL | | |
| DATE: | DWG: VACUUM | FIG: 109 |