



- NOTES:
1. (*) : 15" MAX. FOR PIPE DIAMETER LESS THAN 24", AND 24" MAX. FOR PIPE DIA. 24" AND OVER.
 2. "D" REFERS TO THE DIAMETER OF THE PIPE.
 3. "T" REFERS TO THE THICKNESS OF THE PIPE.
 4. USE OF CONCRETE ARCH HALF ENCASUREMENT OR FULL ENCASUREMENT TO BE DETERMINED IN THE FIELD AS DIRECTED BY THE CITY.
 5. REFER TO SECTION 32.5 OF THE MANUAL FOR SHEETING AND BRACING EXCAVATIONS.

CITY OF OCOEE UTILITIES DEPARTMENT
 CONCRETE ARCH AND
 ENCASUREMENT DETAILS