



NOTES:

1. ALL PIPE SHALL REQUIRE #10 THHN SOLID COPPER TRACING WIRE CAPABLE OF DETECTION BY A CABLE LOCATOR
2. AND SHALL BE BURIED DIRECTLY ABOVE THE CENTERLINE OF THE PIPE. LOCATING WIRE SHALL TERMINATE AT THE TOP OF EACH VALVE BOX
3. AND BE CAPABLE OF EXTENDING 12" ABOVE TOP OF BOX IN SUCH A MANNER SO AS NOT TO INTERFERE WITH VALVE OPERATION. USE DUCT TAPE AS NECESSARY TO HOLD WIRE DIRECTLY ON THE TOP OF THE PIPE.
4. EARLY WARNING TAPE MAY BE REQUIRED IN ADDITION TO LOCATING WIRE AT DIRECTION OF CITY.

* CITY OF OCOEE UTILITIES DEPARTMENT			
PIPE LOCATING WIRE DETAIL			
DATE	MAY 2009	DWG:	PLWD
FIG:	108		