



NOTES:

- 1. ALL 2" PIPE AND FITTINGS SHALL BE SCHEDULE 40 GALVANIZED STEEL OR BRASS WITH THREADED (NPT) JOINTS.

CITY OF OCOEE UTILITIES DEPARTMENT		
BLOWOFF VALVE DETAIL		
DATE:	AUG. 1990	DWG: BOVD
		FIG: 403