



- NOTES:
1. THE CONTRACTOR SHALL CONTACT THE INSPECTOR FOR EXACT ASSEMBLY LENGTH AND HEIGHT ABOVE THE SLAB REQUIRED FOR THE FIRE LINE MASTER METER TO BE INSTALLED BY THE CONTRACTOR. ALL OTHER PIPE, FITTINGS AND APPURTENANCES SHALL BE INSTALLED BY THE CONTRACTOR.
  2. ALL ABOVE GROUND PIPE SHALL BE FLANGED DUCTILE IRON.
  3. FIRE LINE MASTER METER TO BE APPROVED BY THE CITY PRIOR TO PURCHASE OR INSTALLATION.

CITY OF OCOEE UTILITIES DEPARTMENT

FIRE LINE MASTER METER ASSEMBLY