



NOTES:

1. PVC EXTENSIONS SHALL NOT BE USED ON VALVE BOX INSTALLATION.
2. THE ACTUATING NUT FOR DEEPER VALVES SHALL BE EXTENDED TO COME UP TO 2 FOOT DEPTH BELOW FINISHED GRADE.

CITY OF OCOEE UTILITIES DEPARTMENT		
GATE VALVE AND BOX DETAIL		
DATE:	MAY 2009	DWG: GVBOX
		FIG: 400