



NOTES:

1. MANHOLE SHOWN IS FOR SEWER SIZE 8" THRU 24", SEE SECTION 20.4.3 OF THE MANUAL FOR MANHOLE DIAMETER FOR SEWERS LARGER THAN 24".
2. DROP CONNECTIONS ARE REQUIRED WHENEVER INVERT OF INFLUENT SEWER IS 24" OR MORE ABOVE THE INVERT OF THE MANHOLE. SEE MANHOLE CONNECTION DETAILS.
3. APPROVED CONCENTRIC CONE DESIGN MAY BE USED AS AN ALTERNATIVE.

CITY OF OCOEE UTILITIES DEPARTMENT

PRECAST CONCRETE MANHOLE
PLAN AND SECTION

DATE: 04/01/92

DWG:

FIG: 200A