



- NOTES:
1. ALL PIPE AND FITTINGS 2" AND SMALLER SHALL BE THREADED SCHEDULE 40 GALVANIZED STEEL OR BRASS.

CITY OF OCOEE UTILITIES DEPARTMENT		
REDUCED PRESSURE BACKFLOW PREVENTER		
DATE:	AUG. 1990	DWG: BPSS
		FIG: 501