



NOTE: USE ENCASEMENT WHERE VERTICAL CLEARANCE BETWEEN WATER MAIN AND SEWER IS LESS THAN 12". DUCTILE IRON PIPE MAY BE USED IN LIEU OF CONCRETE ENCASEMENT AT SEWER LINE CROSSING WITH A LENGTH OF PIPE CENTERED AT THE POINT OF CROSSING, SO AS TO LOCATE JOINTS AT A MAXIMUM DISTANCE FROM THE SEWER LINE.

CITY OF OCOEE UTILITIES DEPARTMENT

UTILITY CROSSING  
CONCRETE ENCASEMENT