



- NOTES:
1. ALL FITTINGS SHALL BE BRASS WITH COMPRESSION/PACK JOINT TYPE CONNECTIONS.
  2. NO SERVICE LINE SHALL TERMINATE UNDER A DRIVEWAY.
  3. EACH SERVICE SHALL TERMINATE AT A CURB STOP(S) WHICH SHALL BE EXPOSED APPROXIMATELY 3' ABOVE FINAL GRADE AND TIED TO A 2" x 4" x 4" STAKE WITH THE TOP PAINTED BLUE(POTABLE) OR PURPLE(REUSE) AND MARKED WITH THE NUMBER OF THE LOT(S) TO BE SERVED.
  4. SAWCUT "W" IN CURB FOR LOCATION OF POTABLE WATER SERVICE.
  5. CONTRACTOR IS TO USE A HOLE SAW AND REMOVE COUPON WHEN SADDLE IS USED.
  6. DIRECT TAP OR SADDLE MAY BE USED ON D.I.P.
  7. SERVICES SHALL BE DIRECTIONAL DRILLED OR PULLED. NO OPEN CUT SERVICES.

CITY OF OCOEE UTILITIES DEPARTMENT		
WATER SERVICE CONNECTION DETAILS		
DATE:	MAY 2009	DWG: SERVCONN
FIG:	405	